

September 14, 2026

DENA 332037 | 227793

Eielson Visitor Center Rehabilitation

Denali National Park, Alaska

Re: Amendment 0003: Design Addendum 01

The Contract Documents for DENA 332037 Eielson Visitor Center Rehabilitation, Denali National Park, Alaska are amended as follows; all other terms and conditions remain unchanged.

ADDENDA No. 1		
Item No.	Reference	Change
GENERAL		
AD1.1		ADD accompanying 2008 sprinkler as-builts for reference
AD1.2		REPLACE Pricing Schedule
SPECIFICATIONS		
AD1.3	Index	ADD accompanying specs
AD1.4	01 26 01	REPLACE PAGE 7 accompanying Spec 01 26 01 Contract Modification Procedures
AD1.5	01 27 00	REPLACE accompanying spec 01 27 00 Definition of Contract Line Items
AD1.6	02 41 19	REPLACE PAGE 1-3 accompanying spec 02 41 19 Selective Demolition
AD1.7	12 36 00	ADD accompanying spec 12 36 00 Countertops
AD1.8	02 85 00	ADD accompanying spec 02 85 00 Microbial Remediation
AD1.9	26 30 00	REPLACE accompanying spec 26 30 00 Facility Electrical Power Generating and Storing Equipment
AD1.10	07 52 16	REPLACE with the accompanying spec 07 52 16
AD1.11	05 50 00	REPLACE with the accompanying spec 05 50 00

DENA 332037
Eielson Visitor Center Rehabilitation
Denali National Park, Alaska
Addendum #1

AD1.12	31 20 00	ADD accompanying spec 31 20 00 Earth Moving
AD1.13	32 96 13	REPLACE with the accompanying spec 32 96 13
AD1.14	21 13 00	REPLACE with the accompanying spec 21 13 00
DRAWINGS		
AD1.15	3/E202	DELETE the motor symbol with Specific Sheet Note #2 for condensate pump, which has been removed from mechanical scope.
AD1.16	3/E202	DELETE the receptacle tagged with Specific Sheet Note #3. Replace this receptacle with a hardwired power connection connected to circuit "B-11" and a new Specific Sheet Note #3, "PROVIDE HARDWIRED CONNECTION FOR TRAP-PRIMER (TP-1)."
AD1.17	1/E202	ADD motor connection with motor rated switch in Mech room 110, with a new Specific Sheet Note #17, "PROVIDE MOTOR CONNECTION FOR NEW 38W PUMP (THWP-1). PUMP IS AN "ECM" UNIT WITH INTEGRAL OVERLOADS. EXTEND THE EXISTING ROOM CIRCUIT "B-23" TO POWER THE NEW MOTOR."
AD1.18	E001 Lighting Fixture Schedule	CHANGE Fixture type 'T3': the complete basis of design light fixture model should read "CORONET LIGHTING / CRD1S-DS\2-ED\1-ST\4-30-MED-UNV-DR96-W-ACP-MB-SD, OR APPROVED EQUAL".

END OF ADDENDUM 01