

Addendum #1

To: All Potential Proposers
From: Lindsay McClure, MCEDD Energy & Project Manager
Date: September 3, 2026
Subject: Cascade Locks Fire Station Solar + Storage Energy System Construction RFP

The City of Cascade Locks is providing this Addendum to confirm, clarify, or amend certain provisions of the Request for Proposals.

Page 6 of the Request for Proposals document, under Warranties, Performance Standards, and Performance Guarantees, includes a bullet that currently reads as follows:

- Capacity: Guarantee the BESS delivers 440 kWh of usable energy at the time of substantial completion (verified by a full discharge test).

This addendum amends this bullet to read as follows:

- Capacity: Guarantee the BESS delivers at least 110 kWh of usable energy at the time of substantial completion (verified by a full discharge test).

This addendum makes no other changes to the RFP. All other terms, requirements, and deadlines remain unchanged and in full effect.