

ExxonMobil
Fuels Marketing
DIVISION OF EXXON MOBIL CORPORATION

**U.S. Region
Engineering**

COPYRIGHT © 2001 EXXON MOBIL CORP.
ALL RIGHTS RESERVED

**U.S. Region
Engineering**

Project Tank, Piping, Dispenser and Related Electrical Installation Drawings

Design Type
JUST
Building Type / Size:
Building Style:
Bldg. Codes Series:
Drawn By / Approved By:
File Name: JAK/LRG
Notes: 70020DP0
 1/10/05
Issued For: Standard

Project No.
70010D

row No.
PO.0

Scope Item	Included in Scope ? y/n	Size	Quantity	Description/Comments
Supreme Unleaded Tank				
Plus Unleaded Tank				
Regular Unleaded Tank				
Diesel Tank				
Tank Anchoring Method				
Sheet Piling Req'd				
Depth of Water Table				
Excavation Dewatering ?				
Number of MPD's / Brand				
Non-Blending/Blending				
Product Piping Type				
-				
Flex Connectors:				
Dispensers				
Sub Pumps				
Vents				
-				
STP Manufacturer				
Remote fills				
Stage II Vapor Recovery				
Overfill setting for ball floats- 90% , 30 minute rule				

Project	Sheet	Description
70010D	P0.0	Cover Sheet
70010D	P1.0	Specifications
70010D	P2.0	Equipment Schedule
70010D	P3.0	Tank Standards
70010D	P4.0	Tank Equipment Details
70010D	P5.0	Tank Equipment Details
70010D	P6.0	Environ Piping Coaxial System
70010D	P7.0	Fiberglass Piping
70010D	P8.0	Fill/Vapor Containment & FG VR Piping
70010D	P9.0	Dispenser Base Drawings
70010D	P10.0	Remote Fills
70010D	P11.0	Vent Details & Observation Well Details
70010D	P12.0	Fuel System Yard Electrical
70010D	P13.0	Typical Island Requirements