

Equipment Schedule		ExxonMobil Supplied
1	Double Wall Fiberglass Tank with Brine filled interstice	Containment Solutions
2	STP Containment Sump	Containment Solutions WTE look up riser height from table on p.0 -- 32" reducer on Fill Sump liquid tight lid on pump sump
3	Containment Sump Penetration Seals	Environ -- see schedule on p.0
5	Submersible Pump	Gasoline : Red Jacket 2.0 hp fixed speed, QS2 Length, 27" riser and trapper filter. Diesel : Red Jacket 1.5 HP fixed speed, QS2 Length, 27" riser and trapper filter Gasoline : Red Jacket 2.0 hp fixed speed, QS1 Length, 27" riser and trapper filter. Diesel : Red Jacket 1.5 HP fixed speed, QS1 Length, 27" riser and trapper filter
6	REFLECTIVE MARKER	EBW 787-201 Order one per fill/vapor connection with color code per product
7	Ball Valve 2"	Universal #213-FP20
8	Optional Flexible Connector 2"x12"	Titeflex Firesafe 111877E-24-0120
8A	Optional Flexible Connector 2"x26"	Titeflex Firesafe 11504E-32-0260
9	Optional Flexible Connector 1.5"x12"	Titeflex Firesafe 111504E-32-1020
9A	Optional 3"x12" Flex Connector	Titeflex Firesafe 111504D-48-0120
10	Pomeco 42" multiport lid/spill bucket assembly including fill/vapor fittings & 5 gallon spill buckets	Ⓐ 6571EVRB-164042RT052 for gasoline and vapor connections ⒶⒹ 6571EVRL-164042RT051 for diesel. Also for gasoline with remote fills Ⓑ Bronze Vapor Swivel Adapter 61VSA-1020-EVR Ⓒ Bronze Swivel Fill Adapter 61SALP-1020-EVR Ⓓ Cap for Fill Pipe 634TT-7085-EVR Ⓔ Cap for Vapor Pipe 1711T-7085-EVR Ⓕ Face Seal Adapter FSA-400-S Ⓖ Jack screw assembly 61JSK-4400-EVR Ⓗ 4" Nipple 4" long for vapor bucket VPN4x4 Ⓘ 4" Nipple 5.5" long for fill bucket VPN4x5 Ⓢ Riser Spacer 16" C-C 6511-RB16 Ⓧ Sump Shield for 32 1/2" sump top MPWS-33
11	5 gallon spill bucket for remote vapor lines	561L-RM20RT051PL-X
12	5 gallon spill bucket for direct fill lines	561L-RM20RT051-X
13	Fill bucket marker strips	Pannier -- Order one per fill/vapor connection with color code for product
14	Drop Tube for 8' (2438mm) tanks 4"x12" (101.6mm x 3658mm)	OPW 61T-7268
14A	Drop Tube for 10' (3048mm) tanks 4"x15" (101.6mm x 4572mm)	OPW 61T-7368
14B	Drop Tube for 10' (3048mm)tanks over 5' (1524mm)deep 4"x17" (101.6mm x 5182mm)	OPW 61T-7468
15	Dispenser Pipe Bollard	Formex
16	Stainless Steel Island Forms	Formex
18	Extractor Fitting-Cross 4x4x3x3	OPW 233VM-4433
19	Float OverFill Vent Valve	Environ F V V
20	Monitoring Well Hardware	Morrison 519 - 12"(304.8mm) manhole & 678XA 4"(101.6mm) Plug
21	Remote Fill Drop tube anchor	OPW 61-JSK-4RMT - Contractor furnishes T
22	Vent Containment Sump	Environ PTS-2922
23	Manhole & Cover 18" (457.2mm)	CNI 7026C with Camlocks
24	Manhole & Cover 42" (1067mm)	CNI 7046 with Camlocks and Easylift
25	Emergency Shut-off valve Double poppet	OPW 10-BUP-5926 FOR WAYNE DISPENSERS OPW 10-BHMP-5830 FOR GILBARCO DISPENSERS
26	Vapor Line Shear Section Double Poppet	OPW 60VSP-1001
27	Dispenser Sump	Environ deep or extended sump. Order for dispenser type and required depth. Requires site specific review.
28	Vent Rain Cap for Non-Stage 2 tanks	2" (50.8mm) - OPW 23-0033 3" (76.2mm) - OPW 23-0055
29	3" (76.2mm)Vent Valve for tanks with Wayne or Gilbarco Vac Assist Stage 2 - Thread-on	OPW 623V-3203
30	Tank Guage Riser Cap & Adapter	VR 312020-952
31	Vapor Return Piping Trap	Western Fiberglass "Vapor Pot" Specify vertical or horizontal orientation design
32	Containment Sump Sensor - STP / MPD	Veeder-Root 857080-101 Gas 12" for MPD's Veeder-Root 857080-102 Gas 24" for STP sump Veeder-Root 857080-111 Diesel 12" for Diesel Disp Veeder-Root 857080-112 DIESEL 24" for STP sump
33	Tank Gauge Magnetostrictive Level probe	Veeder-Root 8' tank 847390-107 10' tank 847390-109
34	Brine filled Sump Sensor	Veeder-Root 794380-302
35	Pressurized line leak detector	Veeder-Root 848480-002 for Red Jacket STP
36	Non-Vented Check Valve	Veeder-Root 330020-416
37	Dispenser sump fire extinguisher	Environ AFE-2000

Loop

Seal

Revision
Number
Description
Date
Initials

Project
Tank, Piping, Dispenser and Related
Electrical Installation Drawings
Specifications and Equipment
Schedules

RAS Number
Design Type
UST
Building Type / Size:
Building Style:
Bldg. Code: Scale:
Drawn By / Approved By:
File Name: JAK/LRG
Date: 70010DP2
Issued For: 1/10/05
Standard
Project No.
70010D
Drawing No.
P2.0