

VIBRATION ISOLATION SCHEDULE FOR HVAC PIPING AND EQUIPMENT							
ISOLATED EQUIPMENT	DESCRIPTION		AC UNIT, PACKAGED	AIR HANDLING / MAKEUP AIR UNITS	AC UNIT, SPLIT SYSTEM DX INDOOR	FAN, INLINE CENTRIFUGAL	DUCTWORK
	TAG NUMBERS		DOAU-01/DOAU-02	XX-MAU-XX	XX-AC-XX	XX-EF-XX	
	LOCATION		GROUND	GROUND	SUSPENDED	SUSPENDED	SUSPENDED
VIBRATION ISOLATOR	TYPE		NONE	NONE	NONE	SPRING HANGER	NONE
	MINIMUM DEFLECTION	INCH				1	
EQUIPMENT BASE	TYPE		STRUCTURAL STEEL BASE	STRUCTURAL STEEL BASE	NONE	NONE	NONE
FLEXIBLE CONNECTOR	TYPE		FLEXIBLE DUCT CONNECTOR - POLYCHLOROPRENE	FLEXIBLE DUCT CONNECTOR - POLYCHLOROPRENE	NONE	FLEXIBLE DUCT CONNECTOR - POLYCHLOROPRENE	NONE
	MINIMUM DEFLECTION	INCH	1	1		1	
ISOLATED EQUIPMENT	DESCRIPTION		AIR HANDLING / MAKEUP AIR UNITS	AC UNIT, PACKAGED	AC UNIT, SPLIT SYSTEM DX OUTDOOR	AC UNIT, PACKAGED	UNIT HEATERS
	TAG NUMBERS		80-MAU-XX	AHU-1	CU-XX		UH-XX
	LOCATION		ROOF	GROUND	GROUND	GROUND	SUSPENDED
VIBRATION ISOLATOR	TYPE		NONE	NONE	NONE		NONE
	MINIMUM DEFLECTION	INCH					
EQUIPMENT BASE	TYPE		ROOFTOP ISOLATION CURB	NONE	NONE	STRUCTURAL STEEL BASE	NONE
FLEXIBLE CONNECTOR	TYPE		FLEXIBLE DUCT CONNECTOR - POLYCHLOROPRENE	FLEXIBLE DUCT CONNECTOR - POLYCHLOROPRENE	NONE	FLEXIBLE DUCT CONNECTOR - POLYCHLOROPRENE	NONE
	MINIMUM DEFLECTION	INCH	1	1		1	
REMARKS:							
A: PROVIDE THRUST LIMITS ON ALL UTILITY BLOWERS AND SUSPENDED FANS OPERATING AT 3 INCHES SP AND HIGHER							

ISOLATED EQUIPMENT	DESCRIPTION		AIR HANDLING / MAKEUP AIR UNITS	AC UNIT, SPLIT SYSTEM DX OUTDOOR		
	TAG NUMBERS		80-MAU-01/02	XX-CU-XX		
	LOCATION		ROOF	GROUND		
VIBRATION ISOLATOR	TYPE		NONE	ELASTOMERIC PAD		
	MINIMUM DEFLECTION	INCH				
EQUIPMENT BASE	TYPE		ROOFTOP ISOLATION CURB	NONE		
FLEXIBLE CONNECTOR	TYPE		FLEXIBLE DUCT CONNECTOR - POLYCHLOROPRENE	NONE		
	MINIMUM DEFLECTION	INCH	1			
REMARKS: A: PROVIDE THRUST LIMITS ON ALL UTILITY BLOWERS AND SUSPENDED FANS OPERATING AT 3 INCHES SP AND HIGHER						