

DUCTWORK SCHEDULE

SYSTEM	SERVICE	SECTION	SMACNA DUCT CONSTRUCTION CRITERIA			SMACNA LEAKAGE TESTING CRITERIA				APPLICABLE REMARKS
			PRESSURE CLASS (IN W.G.)	MATERIALS OF CONSTRUCTION	SEAL CLASS	QUANTITY TO TEST PERCENT	TEST PRESSURE IN W.G.	LEAKAGE CLASS (CL)	LEAKAGE FACTOR (F) CFM/100 SF	
12-AHU-01 AIR HANDLER CONSTANT AIR VOLUME	SUPPLY AIR	ALL	2	GALVANIZED STEEL	B	100	2	24		
	OUTDOOR AIR	ALL	-2	GALVANIZED STEEL	B	100	-2	24		
	RETURN AIR	ALL	-2	GALVANIZED STEEL	B	100	-2	24		
EF-XXX EXHAUST FAN	EXHAUST AIR	FROM EXHAUST GRILLE TO FAN	-2	GALVANIZED STEEL	B	100	-2	24		
	EXHAUST AIR	FROM FAN TO OUTLET	2	GALVANIZED STEEL	B	100	-2	24		
10-EF-02	HOOD EXHAUST	ALL	-2	STAINLESS STEEL	B	100	-2	24		
10-EF-03	HOOD EXHAUST	ALL	-2	STAINLESS STEEL	B	100	-2	24		
10-DOAU-01	SUPPLY AIR	ALL	2	GALVANIZED STEEL	B	100	2	24		
10-DOAU-02	SUPPLY AIR	ALL	2	GALVANIZED STEEL	B	100	2	24		
20-EF-01	EXHAUST AIR	ALL	-2	STAINLESS STEEL	B	100	-2	24		
20-MAU-01	SUPPLY AIR	ALL	2	STAINLESS STEEL	B	100	2	24		
32-SF-01	SUPPLY AIR	ALL	2	STAINLESS STEEL	B	100	2	24		
32-EF-04	EXHAUST AIR	ALL	-2	STAINLESS STEEL	B	100	-2	24		
32-MAU-01	SUPPLY AIR	ALL	2	ALUMINUM	B	100	2	24		
32-MAU-02	SUPPLY AIR	ALL	2	ALUMINUM	B	100	2	24		
80-MAU-01	SUPPLY AIR	ALL	2	ALUMINUM	B	100	2	24		
80-MAU-02	SUPPLY AIR	ALL	2	ALUMINUM	B	100	2	24		

DUCTWORK SCHEDULE

SYSTEM	SERVICE	SECTION	SMACNA DUCT CONSTRUCTION CRITERIA			SMACNA LEAKAGE TESTING CRITERIA				APPLICABLE REMARKS
			PRESSURE CLASS (IN W.G.)	MATERIALS OF CONSTRUCTION	SEAL CLASS	QUANTITY TO TEST PERCENT	TEST PRESSURE IN W.G.	LEAKAGE CLASS (CL)	LEAKAGE FACTOR (F) CFM/100 SF	
80-EF-01	EXHAUST AIR	ALL	-2	ALUMINUM	B	100	-2	24		
80-EF-02	EXHAUST AIR	ALL	-2	ALUMINUM	B	100	-2	24		
FA DUCT	FOUL AIR	ALL	-2	316 STAINLESS STEEL	B	100	-2	24		A, B
SYSTEMS NOT ADDRESSED ABOVE	ALL	ALL	2	GALVANIZED STEEL	B	100	2	24		
REMARKS: A: REFER TO PIPING SCHEDULE FOR ADDITIONAL REQUIREMENTS. B: INDOOR EXPOSURE ONLY.										